



EC CERTIFICATE

Notified Body No. 0843

CPR Notified Body UL International (UK) Ltd., Wonersh House, The Guildway, Old Portsmouth Road, Guildford, Surrey, GU3 1LR, United Kingdom

Certificate of constancy of performance, 0843-CPR-0406

In compliance with the Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

K-FLEX K-FIRE BOARD

Penetration Seal Classified for use in flexible & solid walls and solid floors

A board used to seal around cables and metallic pipes to form a penetration seal to reinstate the fire resistance performance of wall and floor constructions, where they have been provided with apertures for the penetration of services. K-FLEX K-FIRE BOARD is supplied coated on one face, referenced 1-S, or on both faces, referenced 2-S. The board or boards are then cut to allow the penetration of the required services, before being inserted into the aperture in the wall or floor.

placed on the market under the name or trade mark of

L'ISOLANTE K-FLEX S.p.A.

Via Don G. Locatelli 35, 20877, Roncello, MB Italy

and produced in the manufacturing plant(s)

A/003

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in the

ETA 17/1022, issued on 21/12/2017

and

ETAG 026-2 (used as an EAD)

under system AVCP 1 for the performance set out in the ETA are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 21st December 2017 and will remain valid as long as neither the ETA, the EAD, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

21st December 2017

Mr. Chris Johnson, Staff Engineer

UL International (UK) Limited
Wonersh House, The Guildway, Old Portsmouth Road,
Guildford, Surrey, GU3 1LR, United Kingdom

27-CP-F0855 Issue: 1.1



EC CERTIFICATE

Notified Body No. 0843

CPR Notified Body UL International (UK) Ltd., Wonersh House, The Guildway, Old Portsmouth Road, Guildford, Surrey, GU3 1LR, United Kingdom

Annex: Detailed information sheet

Certificate Number: 0843-CPR-0406

Product/Device description: K-FLEX K-FIRE BOARD

Applicant designation: L'ISOLANTE K-FLEX S.p.A., Via Don G. Locatelli 35, 20877, Roncello, MB Italy

Product Information

K-FLEX K-FIRE BOARD
Coated board

The referenced product complies with:

A – All the relevant requirements as per ETA 17/1022

ETA valid issue date:

ETA 17/1022, issued on 21/12/2017

21st December 2017

Mr. Chris Johnson, Staff Engineer